

Translation

(1) EC-Type Examination Certificate

(2) Equipment and protective systems intended for use
in potentially explosive atmospheres - Directive 94/9/EC

(3) No. of EC-Type Examination Certificate: **BVS 12 ATEX E 053 X**

(4) Equipment: **DIN Rail Isolator type D5072*, D5072*-xxx, D5273S, D5273S-xxx**

(5) Manufacturer: **G.M. International S.R.L.**

(6) Address: **Via San Fiorano 70, 20852 Villasanta (MB), Italy**

(7) The design and construction of this equipment and any acceptable variation thereto are specified in the appendix to this type examination certificate.

(8) The certification body of DEKRA EXAM GmbH, notified body no. 0158 in accordance with Article 9 of the Directive 94/9/EC of the European Parliament and the Council of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive. The examination and test results are recorded in the test and assessment report BVS PP 12.2099 EG.

(9) The Essential Health and Safety Requirements are assured by compliance with:

EN 60079-0:2009	General requirements
EN 60079-11:2012	Intrinsic safety 'i'
EN 60079-15:2010	Type of protection 'n'
EN 60079-26:2007	Equipment with equipment protection level (EPL) Ga
EN 50303:2000	Equipment Group I Category M1

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the appendix to this certificate.

(11) This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment in accordance to Directive 94/9/EC.
Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.

(12) The marking of the equipment shall include the following:



I or II extended with the applicable category- and type of protection-marking; see tables in 15.1

DEKRA EXAM GmbH
Bochum, dated 10.07.2012

Signed: Simanski

Certification body

Signed: U. Hauke

Special services unit

15.3 Parameters

15.3.1 Non intrinsically safe circuits

15.3.1.1 Power supply

DIN Rail Isolator version	Voltage		Power
	U_n	U_m	P_n
	DC [V]	AC [V]	[W]
D5072S, D5072S-xxx	24	250	≤ 1
D5072D, D5072D-xxx	24	250	≤ 1.5
D5273S, D5273S-xxx	24	250	≤ 1.5

15.3.1.2 Input / output signal circuits

Voltage $U_m =$ AC 250 V

15.3.2 Intrinsically safe circuits level of protection Ex ia IIC / IIB / IIA / I / IIIC

15.3.2.1 Temperature Converter type D5072S, D5072S-xxx, D5072D, D5072D-xxx Level of protection: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

15.3.2.2 Temperature Converter and Trip Amplifier type D5273S, D5273S-xxx Level of protection: Ex nA nC [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

Single channel parameters		DIN Rail Isolator type		
		D5072S, D5072S-xxx	D5072D, D5072D-xxx	D5273S, D5273S-xxx
Channel / Terminals	1	7-8-9-10	7-8-9	13-14-15-16
	2	N / A	10-11-12	N / A
Voltage U_o		DC 7,2 V	DC 7,2 V	DC 7,2 V
Current I_o		23 mA	16 mA	23 mA
Power P_o		40 mW	27 mW	40 mW
Voltage U_i		DC 12.8 V	DC 12.8 V	DC 12.8 V
Current I_i		28.7 mA	N / A	28.7 mA
Power P_i		N / A	N / A	N / A
Effective internal capacitance C_i		0 nF	0 nF	0 nF
Effective internal inductance L_i		0 nH	0 nH	0 nH
Max. external capacitance C_o	IIC	13.5 μ F	13.5 μ F	13.5 μ F
	IIB IIIC	240 μ F	240 μ F	240 μ F
	IIA	1000 μ F	1000 μ F	1000 μ F
	I	1000 μ F	1000 μ F	1000 μ F
Max. external inductance L_o	IIC	67.2 mH	138 mH	67.2 mH
	IIB IIIC	268.8 mH	555 mH	268.8 mH
	IIA	537.7 mH	1111 mH	537.7 mH
	I	882.2 mH	1822 mH	882.2 mH
Max. inductance / resistance ratio L_o/R_o	IIC	0.875 mH/ Ω	1.29 mH/ Ω	0.875 mH/ Ω
	IIB IIIC	3.5 mH/ Ω	5.16 mH/ Ω	3.5 mH/ Ω
	IIA	7 mH/ Ω	10.33 mH/ Ω	7 mH/ Ω
	I	11.48 mH/ Ω	16.95 mH/ Ω	11.48 mH/ Ω
Characteristics		linear	linear	linear
Ambient temperature range		$-40^\circ\text{C} \leq T_a \leq +70^\circ\text{C}$		
Remark:		N / A = not applicable		

(16) Test and Assessment Report
BVS PP 12.2099 EG as of 10.07.2012

(17) Special conditions for safe use

17.1 Group I application

DIN Rail Isolators of type series D5****, D5****-xxx shall be installed outside the hazardous area or alternatively in an enclosure providing a suitable type of protection according to separate certification.

For Group I application interconnection of DIN Rail Isolators of type series D5****, D5****-xxx with other electrical apparatus to an intrinsically safe electrical system shall be assessed in a System Certificate if required in local installation rules.

17.2 Group II application (Gas)

DIN Rail Isolators of type series D5****, D5****-xxx shall be installed:

- outside the hazardous area, or
- shall be mounted inside an enclosure, which is in accordance with EN 60079-15:2010 in case of alternative installation in areas requiring EPL Gc equipment.

17.3 Group II application (Dust)

DIN Rail Isolators of type series D5****, D5****-xxx shall be installed outside the hazardous area.

17.4 General

The installation of DIN Rail Isolators of type series D5****, D5****-xxx shall be carried out in such a way that the clearances of bare conductors of intrinsically safe circuits to grounded metal parts of the enclosure are at least 3 mm, and bare conductors of non-intrinsically safe circuits of other apparatus are situated at least 50 mm from terminals for external intrinsically safe circuits, or are separated from them by an insulating barrier according to clause 6.2.1 of EN 60079-11:2012.

We confirm the correctness of the translation from the German original.
In the case of arbitration only the German wording shall be valid and binding.

DEKRA EXAM GmbH
44809 Bochum, 10.07.2012
BVS-Scha/Sch A 20120131



Certification body



Special services unit