



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BVS 12.0050X issue No.: 0 Certificate history:

Status: **Current**

Date of Issue: 2012-07-23 Page 1 of 3

Applicant: **G.M. International S.R.L.**  
Via San Fiorano 70,  
20852 Villasanta (MB)  
Italy


Electrical Apparatus: DIN Rail Isolator type D5072S, D5072S-xxx, D5072D, D5072D-xxx, D5273S, D5273S-xxx  
*Optional accessory:*

Type of Protection: Equipment protection by intrinsic safety "i", protection by type of protection "n",  
equipment protection level (EPL) Ga, (EPL) Gc, (EPL) Ma

Marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I  
Ex nAC [ia Ga] IIC T4 Gc

Approved for issue on behalf of the IECEx Certification Body: Dr.-Ing. F. Eickhoff

Position: Deputy Head of Certification Body

Signature:   
(for printed version)

Date: 2012-07-23

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

DEKRA EXAM GmbH  
Dinnendahlstrasse 9  
44809 Bochum  
Germany

 **DEKRA**  
DEKRA EXAM GmbH



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 12.0050X

Date of Issue: 2012-07-23

Issue No.: 0

Page 2 of 3

Manufacturer: **G.M. International S.R.L.**  
Via San Fiorano 70  
20852 Villasanta (MB)  
**Italy**

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 0: General requirements
<b>IEC 60079-11 : 2011-06</b> Edition: 6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-15 : 2010</b> Edition: 4	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
<b>IEC 60079-26 : 2006</b> Edition: 2	Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:


*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

[DE/BVS/ExTR12.0053/00](#)

Quality Assessment Report:

[NO/DNV/QAR07.0005/04](#)



# IECEx Certificate of Conformity

Certificate No.: IECEx BVS 12.0050X

Date of Issue: 2012-07-23

Issue No.: 0

Page 3 of 3

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

#### General product information:

The DIN Rail Isolators provide intrinsically safe supply- and/or signal circuits intended for interconnection to IS equipment installed in hazardous areas requiring Group I, Group IIA, IIB, IIC or Group IIIC equipment. The DIN Rail Isolators are designed as associated apparatus and designated for installation in the safe area or alternatively in areas requiring EPL Gc equipment. Electronic components of DIN Rail Isolators are arranged on printed-circuit-boards (PCB) packaged in plastic enclosures suitable for installation on T35 DIN Rails. The DIN Rail Isolators provide safe galvanic separation between intrinsically safe circuits and non-intrinsically safe signal circuits / non-intrinsically safe power supply on the PCB up to a sum of peak values of rated voltages of 375 V.

#### Description:

Temperature Converter type D5072S, D5072S-xxx, D5072D, D5072D-xxx  
Temperature Converter types D5072S, D5072S-xxx, D5072D, D5072D-xxx provide single or dual channel conversion of intrinsically safe temperature signals (e.g. thermocouples 2, 3, 4 wire resistance temperature detectors RTD), 'mV' sources or transmitting potentiometers from equipment located in potentially hazardous areas. Available versions of the Temperature Converter: single channel: type D5072S, D5072S-xxx. dual channel: type D5072D, D5072D-xxx.

Temperature Converter and Trip Amplifier type D5273S, D5273S-xxx  
Temperature Converter and Trip Amplifier type D5273S, D5273S-xxx provide single channel conversion of intrinsically safe signals produced by temperature sensors (i.e. thermocouples, 2, 3, 4 wires resistances, RTD temperature detectors), 'mV' sources or transmitting potentiometers from equipment located in potentially hazardous areas and repeats, with isolation, the signals to drive a Safe Area/Location load. In addition, two independent alarm trip amplifiers are provided. Each alarm energizes or de-energizes an SPDT relay with a rating up to 250 V, 6 A for alarm functions. The two alarm relays trip points are settable over the entire input signal range. Available versions of the Temperature Converter and Trip Amplifier type D5273S, D5273S-xxx: single channel only.

#### Ratings:

see Annex

#### Type Code:

see Annex

### CONDITIONS OF CERTIFICATION: YES as shown below:

#### 1. Group I application:

DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed outside the hazardous area or alternatively in an enclosure providing a suitable type of protection according to separate certification.

#### 2. Group II application:

DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed:

- outside the hazardous area, or
- shall be mounted inside an enclosure, which is in accordance with IEC 60079-15 in case of alternative installation in areas requiring EPL Gc equipment.

#### 3. Group III application:

DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be installed outside the hazardous area.

#### 4. General

The installation of DIN Rail Isolators of type series D5\*\*\*\*, D5\*\*\*\*-xxx shall be carried out in such a way that the clearances of un-insulated conductors of intrinsically safe circuits to grounded metal parts of the enclosure are at least 3 mm, and un-insulated conductors of non-intrinsically safe circuits of other apparatus are situated at least 50 mm from terminals for external intrinsically safe circuits, or are separated from them by an insulating barrier according to clause 6.2.1 of IEC 60079-11:2011.



# IECEX Certificate of Conformity



Certificate No.: **IECEX BVS 12.0050X**  
**Annex**  
 Page 1 of 2

**Ratings:**

- 1 Non intrinsically safe circuits
- 1.1 Power supply

DIN Rail Isolator version	Voltage		Power
	$U_n$	$U_m$	$P_n$
	DC [V]	AC [V]	[W]
D5072S, D5072S-xxx	24	250	$\leq 1$
D5072D, D5072D-xxx	24	250	$\leq 1.5$
D5273S, D5273S-xxx	24	250	$\leq 1.5$

1.2 Input / output signal circuits

Voltage  $U_m = AC 250 V$

2 Intrinsically safe circuits level of protection Ex ia IIC / IIB / IIA / I / IIIC

2.1 Temperature Converter type D5072S, D5072S-xxx, D5072D, D5072D-xxx

Device marking: Ex nA [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

2.2 Temperature Converter and Trip Amplifier type D5273S, D5273S-xxx

Device marking: Ex nAC [ia Ga] IIC T4 Gc, [Ex ia Da] IIIC, [Ex ia Ma] I

Single channel parameters		DIN Rail Isolator type		
		D5072S, D5072S-xxx	D5072D, D5072D-xxx	D5273S, D5273S-xxx
Channel / Terminals	1	7-8-9-10	7-8-9	13-14-15-16
	2	N / A	10-11-12	N / A
Voltage $U_o$		DC 7,2 V	DC 7,2 V	DC 7,2 V
Current $I_o$		23 mA	16 mA	23 mA
Power $P_o$		40 mW	27 mW	40 mW
Voltage $U_i$		DC 12.8 V	DC 12.8 V	DC 12.8 V
Current $I_i$		28.7 mA	N / A	28.7 mA
Power $P_i$		N / A	N / A	N / A
Effective internal capacitance $C_i$		0 nF	0 nF	0 nF
Effective internal inductance $L_i$		0 nH	0 nH	0 nH
Max. external capacitance $C_o$	IIC	13.5 $\mu$ F	13.5 $\mu$ F	13.5 $\mu$ F
	IIB IIIC	240 $\mu$ F	240 $\mu$ F	240 $\mu$ F
	IIA	1000 $\mu$ F	1000 $\mu$ F	1000 $\mu$ F
	I	1000 $\mu$ F	1000 $\mu$ F	1000 $\mu$ F
Max. external inductance $L_o$	IIC	67.2 mH	138 mH	67.2 mH
	IIB IIIC	268,8 mH	555 mH	268,8 mH
	IIA	537.7 mH	1111 mH	537.7 mH
	I	882.2 mH	1822 mH	882.2 mH
Max. inductance / resistance ratio $L_o/R_o$	IIC	0.875 mH/ $\Omega$	1.29 mH/ $\Omega$	0.875 mH/ $\Omega$
	IIB IIIC	3.5 mH/ $\Omega$	5.16 mH/ $\Omega$	3.5 mH/ $\Omega$
	IIA	7 mH/ $\Omega$	10.33 mH/ $\Omega$	7 mH/ $\Omega$
	I	11.48 mH/ $\Omega$	16.95 mH/ $\Omega$	11.48 mH/ $\Omega$
Characteristics		linear	linear	linear
Ambient temperature range		$-40\text{ }^\circ\text{C} \leq T_a \leq +70\text{ }^\circ\text{C}$		
Remark:		N / A = not applicable		

